

SOUTH EIGHTY

Montana Public Water Supply ID number 04276

2021 Water Quality Report

In compliance with the EPA's Safe Drinking Water Act and in an effort to keep you informed about the quality of water and services we provide to you each day, we're pleased to provide you with our Annual Water Quality Report. This report is a snapshot of the quality of water we provided you last year. It includes details regarding the source of your water, what your water contains and how it compares to EPA and the State of Montana standards.

Our drinking water comes from two wells that are 280 and 415 feet deep. We have 29 service connections and added one new connection last year. We want you, our valued customers, to be informed about your water utility. If you want to learn more, please attend any of our regularly scheduled meetings held on the 3rd Tuesday of each month at 2:00 p.m. at the Lakeside County Water and Sewer District office at 253 Bierney Creek Road in Lakeside.

We are pleased to report that our drinking water is safe and meets all federal and state requirements. If you have any questions about this report or concerning your water utility, please contact Rodney Olson at (406) 844-3881. Our certified operators are Cody Osterday, and Scott Ring who have 10 and five years of experience respectively. They attend periodic training sessions to meet continuing education requirements.

DID YOU KNOW? The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally occurring minerals and in some cases radioactive elements. Water can also pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in water include:

- 1) Microbial contaminants such as viruses and bacteria which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- 2) Inorganic contaminants, such as salts and metals which can be naturally occurring or result from urban storm water runoff, industrial or domestic waste water discharges, oil and gas production, mining and farming.
- 3) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- 4) Volatile organic chemicals, which are byproducts of industrial processes, petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- 5) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health. We take all of our water samples to Montana Environmental Laboratory in Kalispell (406-755-2131). They are a private laboratory that is certified by the State of Montana and the EPA to analyze drinking water.

Our sampling frequency complies with EPA and state drinking water regulations. The following tests were performed to identify possible contaminants in our system during the period of January 1 to December 31, 2021:

- 12 coliform bacteria tests – all were coliform free.
- One nitrate plus nitrite test – result was within EPA guidelines.
- Tests to determine the possible presence of eleven inorganic contaminants – results were within EPA standards.
- Tests to determine the possible presence of 61 organic contaminants – none were detected.
- Tests to determine the possible presence of 40 pesticides & herbicides – none were detected.
- Tests to determine the possible presence of radiological contaminants – results were within EPA guidelines.

The following table lists the contaminants detected during recent testing. Some of the data in this table may be more than one year old, since certain chemical contaminants are monitored less than once per year.

Regulated Contaminants

CONTAMINANT	VIOLATION Y/N	SAMPLE DATE	HIGHEST LEVEL DETECTED	UNIT MEASUREMENT	MCLG	MCL	LIKELY SOURCE OF CONTAMINATION
Barium	N	6-10-21	0.05	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Copper	N	8-6-20	90 th % is 0.10	ppm	1.3	AL= 1.3	Corrosion of Household plumbing / naturally occurring
Fluoride	N	6-10-21	0.09	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth: Discharge from fertilizer and aluminum factories
Nitrate + Nitrite	N	6-10-21	1.24	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Radium 226	N	7-21-16	0.3 +/- 0.1	pCi/L	0	5	Natural deposits
Radium 228	N	7-21-16	1 +/- 0.7	pCi/L	0	5	Natural deposits
Uranium	N	6-10-21	1.7	ppb	0	30	Erosion of natural deposits

DEFINITIONS:

MCL - Maximum Contaminant Level - The “Maximum Allowed” is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG - Maximum Contaminant Level Goal - The “Goal” is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

PPM - Parts per million or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

PPB - Parts per billion or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

AL - Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

pCi/L - Pico Curies per Liter - a very small unit of measurement of radioactivity.

What does this table tell us?

As you can see our system had no MCL violations. MCL's are set at very stringent levels. To understand the possible health effects of exceeding the MCL, a person would have to drink two liters of water every day at the MCL for a lifetime to have a one in a million chance of having any adverse health effects. Although we have learned through our monitoring and testing that some constituents have been detected, the EPA has determined that your water IS SAFE at these levels.

All sources of drinking water are subject to potential contamination by contaminants that are naturally occurring or manmade. Those contaminants can be microbes, organic or inorganic chemicals, or radioactive materials. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791, or online at www.epa.gov/safewater.

Lead in drinking water comes primarily from materials and components of the service lines and home plumbing systems. It is possible that lead levels at your home may be higher than other homes in the community as a result of materials used in your home's plumbing. Our water system is responsible for providing high quality drinking water, but we cannot control the variety of materials used in private home plumbing systems. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested by a certified laboratory like the one we send our samples to (Montana Environmental Laboratory, 406-755-2131). When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap until the water temperature has stabilized (usually for 30 seconds to 2 minutes) before you use the water for drinking or cooking. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure to lead is available from the Safe Drinking Water Hotline 1-800-426-4791, or online at www.epa.gov/safewater/lead.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline, or online at www.epa.gov/safewater.

In February of 2005, the Montana Department of Environmental Quality conducted a source water assessment of our system. This report provides additional information on the potential vulnerability of our wells to contamination. This report is available for review online at <https://deq.mt.gov/water/programs/dw#accordion1-collapse2>. The report can be summarized in the following table:

Significant Potential Contaminant Sources

Source	Contaminant	Hazard	Hazard Rating	Barriers	Susceptibility	Management
Large Capacity Septic Systems (for the development) - Septic Tanks and Leach Fields	Nitrate, pathogens, other contaminants	Catastrophic rupture or chronic leakage of effluent from sewer mains	High Hazard	Depth to well intake below mean static water level; vertically upward groundwater gradient (pressure)	Moderate Susceptibility	Local promotion of advanced septic treatment systems, public education on proper waste disposal, possible development of a community sewer system and wastewater treatment plant
Large Capacity Septic System (for Vista Linda) - Septic Tanks and Leach Fields	Nitrate, pathogens, other contaminants	Catastrophic rupture or chronic leakage of effluent from sewer mains	High Hazard	Depth to well intake below mean static water level; vertically upward groundwater gradient (pressure); well is up gradient from this contaminant source (within the IR)	Moderate Susceptibility	Local promotion of advanced septic treatment systems, public education on proper waste disposal, possible development of a community septic wastewater treatment plant
Sewer Mains (20-50% of IR)	Nitrate, pathogens, other contaminants	Catastrophic rupture or chronic leakage of effluent from sewer mains	Moderate Hazard	Depth to well intake below mean static water level; vertically upward groundwater gradient (pressure)	Low Susceptibility	Public education on proper waste disposal, program of sewer line maintenance; possible development of a community sewer system and wastewater treatment plant
Septic Density - Medium density within and around the perimeter of the IR	Nitrate, pathogens, other contaminants	Leakage of poorly installed or maintained systems	Moderate Hazard	Depth to well intake below mean static water level; vertically upward groundwater gradient (pressure); well is mostly up gradient or lateral to this contaminant source (within the IR)	Low Susceptibility	Local promotion of advanced septic treatment systems, public education on proper waste disposal, possible development of a community sewer system and wastewater treatment plant

Our water system is committed to providing our customers with safe, pure water and we are pleased that our water meets or exceeds all established state and federal standards. Thank you for reviewing this report.

Prepared by Montana Environmental Lab, LLC 3/22



May 19, 2022

**RODNEY OLSON
SOUTH EIGHTY WATER
253 BIERNEY CREEK ROAD
LAKESIDE MT 59922**

RE: Approval of Monitoring Waiver for Asbestos (2020 – 2028), South Eighty Water,
PWSID: MT0004276

Dear Rodney Olson,

DEQ has reviewed the application for an asbestos sampling waiver for South Eighty Water. Based upon the statement that the distribution system does not contain asbestos concrete pipe (AC), DEQ is issuing the monitoring waiver for asbestos sampling in the distribution system (DS001).

Information regarding this asbestos sampling waiver must be included in a Tier 3 Public Notice and must be distributed within one year of the issuance of this waiver and then for each three-year monitoring period for which the waiver applies. Public Notice delivery can be by newspaper, door to door delivery, consumer confidence report enclosure, or by mail to each consumer for CWS's. Posting the notice in a conspicuous location is acceptable for NTNC water systems.

The public notice must include:

- Public water system name and PWSID number;
- Contaminant for which the waiver is granted;
- Monitoring period for which the waiver is in effect; and
- Reasoning for waiver (i.e., distribution system does not contain AC pipe).

Please submit a copy of the public notice to DEQ within one year of the issuance of this waiver. If you have any questions, please contact me at (406) 444-6741 or by email at DJordan3@mt.gov.

Sincerely,

Diane Jordan

Diane Jordan
Chemical/Radiological/Waiver Rule
Manager Public Water Supply

cc: PWS File